



DWS WELL Building Standard V2 Water Test Report

Order number:

Source/Location:

Lab number:

Date Collected:

Name:

Address:

City, State, Zip:

PART 1: Dissolved Metals

Parameter	Limit (mg/L)	MRL (mg/L)	Result (mg/L)
Lead	0.01	0.002	nd
Arsenic	0.01	0.002	nd
Antimony	0.006	0.002	nd
Mercury	0.002	0.0001	nd
Nickel	0.012	0.005	nd
Copper	1	0.2	nd
Cadmium	0.005	0.001	nd
Chromium (Total)	0.1	0.01	nd

PART 2: Organic Pollutants

Parameter	Limit (µg/L)	MRL (µg/L)	Result (µg/L)
Styrene	20	0.38	nd
Benzene	5	0.22	nd
Ethylbenzene	300	0.29	nd
Vinyl Chloride	2	0.5	nd
Toulene	700	0.15	nd
Total xylenes(M,P,O)	500	0.44	nd
Tetrachloroethylene	5	0.2	nd

PART 3: Disinfectant Byproducts

Parameter	Limit (µg/L)	MRL (µg/L)	Result (µg/L)
Total Trihalomethanes	80	0.5	nd
Total Haloacetic Acids	60	0.5	nd

PART 4: Herbicide & Pesticides

Parameter	Limit (µg/L)	MRL (µg/L)	Result (µg/L)
Atrazine	3	0.26	nd
Simazine	2	0.87	nd
2,4-Dichlorophenoxyacetic Acid	70	1	nd



PART 5: Fertilizer

Parameter	Limit (mg/L)	MRL (mg/L)	Result (mg/L)
Nitrates	50	0.3	nd

PART 6: Public Water Additives

Parameter	Limit (mg/L)	MRL (mg/L)	Result (mg/L)
Fluoride	4	0.01	nd
Residual Chlorine	0.6	0.05	nd
Chloramine	4	0.1	nd

All testing performed using USEPA testing methods

Limit = WELL Building Standard V2 threshold concentration standard for each parameter

MRL = Minimum Reporting Level of our test instrument

Result = the actual test result value found in this water sample **if** \geq MRL

mg/L = milligrams per liter; ppm (parts per million)

μ g/L = micrograms per liter

nd = Not detected at or above MRL

Remarks: Parameters highlighted in bold red type are above the standards established in the WELL Building Standard v2

Note: This report is intended to be used for informational purposes only and should not be used for regulatory and/or legal purposes.

By: Thomas Mullen
Laboratory Director