



Dear Drinking Water Specialists Customer,

We are pleased to provide you with the WELL Building Standard V2 Water Test Report for the test kit you sent to us.

This report contains Limits for each parameter tested as specified in the WELL Building Standard V2. The actual Test Result for each parameter is compared to the Limit for that parameter. If the Test Result is greater than the Limit, it is highlighted in **bold red**.

If you have any questions concerning your report, please e-mail us at support@drinkingwaterspecialists.com, or call us at 609.291.9072.

Our goal is to have the WELL Building Standard Water V2 Test Report give you the information you need for your project.

Thank you for putting your trust in ***Drinking Water Specialists***.

Very truly yours,

Michael Beek
Partner



Order number:	Source/Location:
Lab number:	Date Collected:
Name:	
Address:	
City, State, Zip:	
Location:	

	Limit (mg/L)	MRL (mg/L)	Result (mg/L)
Arsenic	0.01	0.002	nd
Cadmium	0.003	0.001	nd
Chromium (total)	0.05	0.01	nd
Copper	2	0.01	nd
Fluoride	1.5	0.2	nd
Lead	0.01	0.002	nd
Mercury (total)	0.006	0.001	nd
Nickel	0.07	0.01	nd
Nitrate as Nitrate	50	0.2	nd
Nitrite	3	0.3	nd
Total chlorine	5		nd
Residual (free) chlorine	4	0.1	nd
Total Trihalomethanes (TTHM)	0.08		nd
Haloacetic Acids (HAA5)	0.06	0.005	nd

Aldrin and Dieldrin (combined)	0.00003		nd
Atrazine	0.1		nd
Chlordane	0.0002		nd
2,4-Dichlorophenoxyacetic acid (2,4-D)	0.03		nd
Dichlorodiphenyltrichloroethane (DDT)	0.001		nd
Lindane	0.002		nd
Pentachlorophenol (PCP)	0.009		nd



WO2 Drinking Water Quality - Part 2, Option 2 Organics

	Limit (mg/L)	MRL (mg/L)	Result (mg/L)
Benzene	0.01	0.005	nd
Benzo[a]pyrene	0.0007	0.005	nd
Carbon tetrachloride: 0.004 mg/L.	0.004	0.005	nd
1,2-Dichloroethane	0.03	0.005	nd
Tetrachloroethene	0.04	0.005	nd
Toluene	0.7	0.005	nd
Trichloroethene	0.02	0.005	nd
2,4,6-Trichlorophenol	0.2	0.005	nd
Vinyl Chloride	0.0003	0.005	nd
Xylenes (o-, m- and p-)	0.5	0.005	nd

W03 Basic Water Management

	Limit	MRL	Result
Turbidity (NTU, FTU or FNU)	1	0.1	nd
pH ¹	6.5 to 9		nd
Residual (free) chlorine	5	0.1	nd
Total coliforms	0		nd

W04 Enhanced Water Quality - Taste

	Limit (mg/L)	MRL (mg/L)	Result (mg/L)
Aluminum	0.2	0.05	nd
Chloride	250	0.2	nd
Copper	1	0.01	nd
Manganese	0.05	0.005	nd
Iron	0.3	0.3	nd
Silver	0.1	0.005	nd
Sodium	270	0.1	nd
Sulfate	250	0.5	nd
Zinc	5	0.01	nd
Total Dissolved Solids (TDS)	500	10	nd
Free Chlorine	1.25		nd



All testing performed using USEPA testing methods

Limit = WELL Building Standard V2 threshold concentration standard for each parameter

MRL = Minimum Reporting Level of our test instrument

Result = the actual test result value found in this water sample ***if*** \geq MRL

mg/L = milligrams per liter; ppm (parts per million)

$\mu\text{g/L}$ = micrograms per liter

nd = Not detected at or above MRL

Remarks: Parameters highlighted in bold red type are above the standards established in the WELL Building Standard v2

Note: This report is intended to be used for informational purposes only and should not be used for regulatory and/or legal purposes.

By: Thomas Mullen
Laboratory Director